

**PHOTOMETRIC DATA:**




**FORUM  
LEGACY**

**CANDLEPOWER  
SUMMARY**

Angle	Candela	Lumens
180	4062	
175	3973	379
165	3973	1128
155	3849	1780
145	3705	2313
135	3339	2534
125	2836	2456
115	2398	2334
105	1692	1721
95	581	604
90	52	
85	19	27
75	26	30
65	32	32
55	39	33
45	45	35
35	58	36
25	58	27
15	65	18
5	58	6
0	52	

**CATALOG NO.:** FP-6-40-120-EL  
**LAMP TYPE:** F40BX  
**LUMENS:** 3150  
**FIXTURE EFFICIENCY:** 68.8%  
**LUMINAIRE WATTS:** 207  
**TEST REPORT NO.:** BAL 6422.1



**COEFFICIENT OF UTILIZATION  
ZONAL CAVITY METHOD**

**EFFECTIVE FLOOR CAVITY REFLECTANCE = 20%**

RC	80				70				50				30			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10		
RCR																
0	78	78	78	78	67	67	67	67	46	46	46	27	27	27		
1	71	68	65	62	61	58	56	53	40	39	37	24	23	22		
2	65	59	54	50	55	51	47	44	35	33	31	21	19	18		
3	59	52	46	42	50	44	40	36	31	28	26	18	17	15		
4	54	46	40	35	46	39	34	31	27	24	22	16	14	13		
5	49	40	34	30	42	35	30	26	24	21	19	14	13	11		
6	45	36	30	26	39	31	26	23	22	18	16	13	11	10		
7	42	33	27	23	36	28	23	20	20	16	14	12	10	09		
8	39	30	24	20	33	25	21	17	18	15	12	11	09	08		
9	36	27	21	18	31	23	19	15	16	13	11	10	08	07		
10	34	25	19	16	29	21	17	14	15	12	10	09	07	06		

Determined in accordance with current IES Published Procedures.

**MOUNTING DETAILS:**

The stems are fitted with an attachment plate and four (4) leveling nuts for joining of the pendant assembly to the fixture body assembly. The pendant assembly is provided with a male electrical connector for ease of wiring with the fixture body assembly.

